

Sample Identification #	Location	Outlet Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units	Remediation Actions
GDS-01-BF-01	126 Bathroom	Bathroom Faucet	10/7/2020 06:57	11/17/2020 09:51	70152961001	Lead	1.4	15	ug/L	
GDS-01-S-DW-06	132 Corridor	Water Fountain	10/7/2020 06:59	11/17/2020 09:54	70152961002	Lead	<1.0	15	ug/L	
GDS-01-DW-13	111 Corridor	Bottle Filler	10/7/2020 07:03	11/17/2020 09:54	70152961003	Lead	1.3	15	ug/L	
GDS-02-BF-18	210c - Left	Bathroom Faucet	10/7/2020 07:12	11/17/2020 09:55	70152961004	Lead	1.8	15	ug/L	
GDS-02-BF-19	210c - Right	Bathroom Faucet	10/7/2020 07:12	11/17/2020 09:58	70152961005	Lead	<1.0	15	ug/L	
GDS-02-BF-20	210 Corridor Women's	Bathroom Faucet	10/7/2020 07:09	11/17/2020 09:59	70152961006	Lead	<1.0	15	ug/L	
GDS-02-BF-21	210 Corridor Men's	Bathroom Faucet	10/7/2020 07:09	11/17/2020 10:00	70152961007	Lead	<1.0	15	ug/L	
GDS-02-DW-22	210 Corridor	Water Fountain	10/7/2020 07:10	11/17/2020 10:01	70152961008	Lead	<1.0	15	ug/L	
GDS-02-BF-23	209c	Bathroom Faucet	10/7/2020 07:16	11/17/2020 10:02	70152961009	Lead	2.4	15	ug/L	
GDS-02-BF-24	209c	Bathroom Faucet	10/7/2020 07:16	11/17/2020 10:02	70152961010	Lead	3.6	15	ug/L	
GDS-02-NIM-P-25	207	Nurse's Ice Machine	10/7/2020 07:20	11/17/2020 10:03	70152961011	Lead	<1.0	15	ug/L	
GDS-02-SF-26	207 Nurse	Sink Faucet	10/7/2020 07:21	11/17/2020 10:04	70152961012	Lead	<1.0	15	ug/L	
GDS-02-CF-30	218	Classroom Sink Faucet	10/7/2020 07:24	11/17/2020 10:05	70152961013	Lead	<1.0	15	ug/L	
GDS-02-CF-31	219	Classroom Sink Faucet	10/7/2020 07:24	11/17/2020 10:06	70152961014	Lead	<1.0	15	ug/L	
GDS-02-DW-32	219 Corridor	Water Fountain	10/7/2020 07:26	11/17/2020 10:09	70152961015	Lead	<1.0	15	ug/L	
GDS-02-BF-33	201B Main Office	Bathroom Faucet	10/7/2020 07:42	11/17/2020 10:46	70152961016	Lead	1.8	15	ug/L	
GDS-02-DW-34	228 Corridor	Water Fountain	10/7/2020 07:44	11/17/2020 10:47	70152961017	Lead	2.7	15	ug/L	
GDS-02-SF-39	233 Faculty	Sink Faucet	10/7/2020 07:45	11/17/2020 10:48	70152961018	Lead	1.0	15	ug/L	
GDS-02-LS-40	238 Library	Sink Faucet	10/7/2020 08:02	11/17/2020 10:48	70152961019	Lead	3.2	15	ug/L	
GDS-02-DW-41	242 Cafeteria	Water Fountain	10/7/2020 07:47	11/18/2020 21:08	70152961020	Lead	2.0	15	ug/L	
GDS-02-BF-42	240 Kitchen	Bathroom Faucet	10/7/2020 07:59	11/17/2020 17:45	70152961021	Lead	6.6	15	ug/L	
GDS-02-SF-43	240 Kitchen	Sink Faucet	10/7/2020 07:59	11/17/2020 17:46	70152961022	Lead	1.9	15	ug/L	
GDS-02-SF-44	240 Kitchen	Corner - Sink Faucet	10/7/2020 07:55	11/17/2020 17:41	70152961023	Lead	21.2	15	ug/L	Result Above Action Level - Faucet replaced
GDS-02-SF-S-44R	240 Kitchen	Corner - Sink Faucet - First Draw	11/2/2021 06:14	11/10/2021 19:08	70193766001	Lead	13.4	15	ug/L	Resampling first draw
GDS-02-SF-S-44F	240 Kitchen	Corner - Sink Faucet - Flush Draw	11/2/2021 06:14	11/10/2021 19:12	70193766002	Lead	2.9	15	ug/L	Resampling flush draw
GDS-02-SF-46	240 Kitchen	Handwashing Sink	10/7/2020 07:51	11/17/2020 17:39	70152961024	Lead	1.1	15	ug/L	
GDS-02-SF-47	240 Kitchen	Sink Faucet - Opposite Stove	10/7/2020 07:51	11/17/2020 17:40	70152961025	Lead	5.7	15	ug/L	
GDS-02-IM-49	240 Kitchen	Ice Machine	10/7/2020 07:55	11/17/2020 17:42	70152961026	Lead	<1.0	15	ug/L	
GDS-02-BF-51	249	Bathroom Faucet	10/7/2020 08:04	11/17/2020 17:47	70152961027	Lead	<1.0	15	ug/L	
GDS-02-SF-52	244 Band	Sink Faucet	10/7/2020 08:06	11/17/2020 17:48	70152961028	Lead	<1.0	15	ug/L	
GDS-02-SF-53	270 (New Wing)	Sink Faucet	10/7/2020 07:34	11/17/2020 10:09	70152961029	Lead	<1.0	15	ug/L	
GDS-02-SF-54	271 (New Wing)	Sink Faucet	10/7/2020 07:30	11/17/2020 10:10	70152961030	Lead	<1.0	15	ug/L	
GDS-02-DW-55	271 (New Wing)	Water Fountain	10/7/2020 07:30	11/17/2020 10:11	70152961031	Lead	<1.0	15	ug/L	
GDS-02-SF-56	272 (New Wing)	Sink Faucet	10/7/2020 07:38	11/17/2020 17:38	70152961032	Lead	<1.0	15	ug/L	
GDS-02-CBF-57	272 Corridor (New Wing)	Bottle Filler	10/7/2020 07:28	11/17/2020 10:12	70152961033	Lead	<1.0	15	ug/L	
GDS-02-BF-58	270 (New Wing)	Bathroom Faucet	10/7/2020 07:34	11/17/2020 10:13	70152961034	Lead	<1.0	15	ug/L	
GDS-02-DW-59	270 (New Wing)	Water Fountain	10/7/2020 07:34	11/17/2020 17:37	70152961035	Lead	<1.0	15	ug/L	
GDS-02-SF-60	271 (New Wing)	Sink Faucet	10/7/2020 07:53	11/17/2020 17:41	70152961036	Lead	<1.0	15	ug/L	
GDS-01-BF-61	135 Faculty Bathroom	Bathroom Faucet	10/7/2020 08:23	11/17/2020 17:49	70152961037	Lead	<1.0	15	ug/L	
GDS-01-BF-62	136 Student Bathroom	Bathroom Faucet	10/7/2020 08:25	11/17/2020 17:49	70152961038	Lead	<1.0	15	ug/L	

NYSDOH Action Level for